

ZHEJIANG ANIX VALVE TECHNOLOGY CO.,LTD

LONGWAN INDUSTRIAL BASE LONGWAN WENZHOU ,(Area 3, Valves Base) CHINA

Mill Test Certificate

Report No.: AN-1905025

Date: May 16th 2019

Order No.:AN-M-2019-0516

TO:Unimech Engineering (M) Sdn Bhd


1. Chemical And Tensile Requirements

Description	Material: ASTM A351 CF8	Heat NO.	QTY (PCS)	Chemical Composition %								Tension Test				
				C	Mn	Si	P	S	Cr	Ni	Mo	Yield Strength ≥205Mpa	Tensile Strength ≥485Mpa	Elongation ≥35%		
2PC Ball Valve With High Mounting Pad and Locking Handle,BSPT,RPTFE,1000 PSI CF8		M9309	5	≤0.08	≤1.50	≤2.00	≤0.04	≤0.04	≤0.04	18-21	8-11	≤0.50		219	519	49

2. Pressure Test And The Results

Detection Project	Media	Measured Values (Mpa)	Duration (s)	Test Results	Results
Shell Test	Water	10.4MPa	≥60	No Leak	Qualified
Seal Test	Air	0.6MPa	≥60	No Leak	Qualified
Test Standard	API 598 (valve inspections and tests)				

We certify that the material has been sampled, tested, and inspected with provisions of the above referenced.



Q.C. Manager: Young Xu