

浙江伊迷莎智控科技有限公司

ZHEJIANG YIMISHA INTELLIGENT CONTROL TECHNOLOGY CO.,LTD.

Laboratory Material Certificate

Report No: ZJYMS20007
 Report Date: 2020.11.23
 P/O NO.: ZJYMS20007-T/ZJYMS20007-M/ZJYMS20007-V
 FIG NO.: BRASS SWING CHECK VALVE

Address: Chumen Yuhuan Sci-Tech Industrial Area
 Zhejiang, China.317605
 Tel: 0576-87427372
 FAX: 0576-87427371


Specificantion(%)

MATERIAL ANALYSIS(%)

Date	Body Logo	Size	Device	Batch No	Specificantion(%)													
					Cu	Pb	Zn	Sn	Fe	Ni	AL	P	Si	Mn	Cr	Bi	Sb	As
2020/11/23	ARITA	1"	ARL3460	141112	57.33	2.77	38.13	0.723	0.68	0.266	0.003	0.006	0.025	0.014	0.003	0.007	0.02	0.013
	ARITA	1-1/4"	ARL3460	141112	57.28	2.69	38.22	0.741	0.79	0.266	0.003	0.005	0.019	0.013	0.003	0.008	0.025	0.018
	ARITA	2"	ARL3460	141112	57.27	2.75	38.21	0.725	0.65	0.265	0.003	0.006	0.026	0.013	0.003	0.007	0.02	0.012

CONCLUSION: This is to certify that all test results are in compliance with the stated specification.

Prepared by
(Sig.&Date)



Authorized by
Quality Manager

(Sig.&Date) 