

*C/I water check AV*

**MATERIAL & TEST CERTIFICATE**

Production Manufacture Name:

LAIZHOU DONGSHENG VALVE CO., LTD

CLIENT:

EN 10204/3.1.B.

ORDER NO:DS2020-MY-104

DATE: 20/02/2021

Item	DESCRIPTION	SIZE	Q'TY	BODY HEAT NO.	Material			Hydrostatic Test		Result
					BODY	DISC	SEAT	BODY	SEAT	
1	Double disc swing check valve	DN40	100	20111	GG25	SS304	EPDM	2.4Mpa	1.76Mpa	OK
2		DN50	104	20111	GG25	SS304	EPDM	2.4Mpa	1.76Mpa	OK
3		DN80	110	20111	GG25	SS304	EPDM	2.4Mpa	1.76Mpa	OK
4		DN100	110	20111	GG25	SS304	EPDM	2.4Mpa	1.76Mpa	OK
5		DN150	100	20111	GG25	SS304	EPDM	2.4Mpa	1.76Mpa	OK
6		DN200	15	20111	GG25	SS304	EPDM	2.4Mpa	1.76Mpa	OK
7		DN250	10	20111	GG25	SS304	EPDM	2.4Mpa	1.76Mpa	OK
8		DN400	6	20111	GG25	SS304	EPDM	2.4Mpa	1.76Mpa	OK
9		DN450	2	20111	GG25	SS304	EPDM	2.4Mpa	1.76Mpa	OK

Item	DESCRIPTION	HEAT NO.	MATERIAL	C%	Si%	Mn%	P%	S%	Cr %	Ni %	HBS	Tensile Strength MPa	Yield Point MPa	ELONGATION E%
1	Body	20111	GG25	3.25	1.64	0.91	0.13	0.08			198	327		

We hereby certify, that the material described above has been tested and complies with the terms of the order contract. INSPECTOR: LI'S