



JOIN FORCE BELLOWS CO., LTD.

MILL CERTIFICATE

CERT NO: JFC2021/02/25

DATE: 25/02/2021




CUSTOMER: EL ETERNAL(TAIWAN)CO.,LTD.


ITEM	MODEL	N.B. (INCH)	QTY	Inspection												Test			
				DN		Length		Flanges		Bellows		Welding		Bolts & Nuts		Pressure			
				accepted	Not accepted	accepted	Not accepted	accepted	Not accepted	accepted	Not accepted	accepted	Not accepted	accepted	Not accepted	accepted	Not accepted		
1	JF150SG	4"	25	√		√		√		√		√		√		√		√	
2	JF150SG	6"	10	√		√		√		√		√		√		√		√	
3	JF150SG	8"	10	√		√		√		√		√		√		√		√	
4	JF150SG	4"	40	√		√		√		√		√		√		√		√	
5	JF150SG	8"	10	√		√		√		√		√		√		√		√	
6	JF150SG	3"	50	√		√		√		√		√		√		√		√	
7	JF150SG	4"	4	√		√		√		√		√		√		√		√	
8	JF150SG	8"	60	√		√		√		√		√		√		√		√	
9	JF250SP	3"	10	√		√		√		√		√		√		√		√	
10	JF250SP	4"	12	√		√		√		√		√		√		√		√	
11	JF250SP	5"	18	√		√		√		√		√		√		√		√	
12	JF250SP	6"	3	√		√		√		√		√		√		√		√	

FINANCIERELLY VERBODEN
HONG KONG BANK LTD

正本
ORIGINAL

Inspection & Test Standard	JF150SG	4"	25	DN100	300±3mm	JIS 10K	16	>3mm	1/2"x3	The test medium is water, test pressure is 1.5 times the design pressure test pressure shall be maintained for 10mins
	JF150SG	6"	10	DN150	300±3mm	JIS 10K	14	>3mm	5/8"x4	
	JF150SG	8"	10	DN200	300±3mm	JIS 10K	13	>3mm	5/8"x4	
	JF150SG	4"	40	DN100	300±3mm	ANSI-150LB	16	>3mm	1/2"x3	
	JF150SG	8"	10	DN200	300±3mm	ANSI-150LB	13	>3mm	5/8"x4	
	JF150SG	3"	50	DN80	300±3mm	PN16	20	>3mm	1/2"x3	
	JF150SG	4"	4	DN100	300±3mm	PN16	16	>3mm	1/2"x3	
	JF150SG	8"	60	DN200	300±3mm	PN16	13	>3mm	5/8"x4	
	JF250SP	3"	10	DN80	330±3mm	—	20	>3mm	—	
	JF250SP	4"	12	DN100	330±3mm	—	16	>3mm	—	
	JF250SP	5"	18	DN125	330±3mm	—	15	>3mm	—	
	JF250SP	6"	3	DN150	330±3mm	—	14	>3mm	—	

NOTE : Four Copies For this material Certificate "DRAWN UNDER HONG LEONG BANK BERHAD, LC NO: LCPR041694, DATED: 18 FEBRUARY 2021"	Company	Manager	Inspector
			



JOIN FORCE BELLOWS CO., LTD.

MILL CERTIFICATE

CERT NO: JFG20210225

DATE: 25/02/2021



1-1,共1頁

CUSTOMER: EL ETERNAL(TAIWAN)CO.,LTD

ITEM	MODEL	QTY	SPEC.				MANUFACTURICHG DATA		MATERIAL						
			N.B (INCH)	TOTAL LENGTH (mm)	AXIAL MOVEMENT (mm)	WORKING PRESSURE (Kg/ cm ²)	DATE	NO.	BELLOWS	FLANGE	INT.SLEEVE	TUBE ENDS	TIE RODS	EXT.COVER	
1	JF150SG	25	4"	300	+10-40	150psi	25/02/2021	L22747 L22748	SUS304	FCD400 JIS 10K	SUS304	—	SS400	—	
2	JF150SG	10	6"	300	+10-40	150psi	25/02/2021	L22747 L22748	SUS304	FCD400 JIS 10K	SUS304	—	SS400	—	
3	JF150SG	10	8"	300	+10-40	16bar	25/02/2021	L22747 L22748	SUS304	FCD400 JIS 10K	SUS304	—	SS400	—	
4	JF150SG	40	4"	300	+10-40	16bar	25/02/2021	L22747 L22748	SUS304	FCD400 150LB	SUS304	—	SS400	—	
5	JF150SG	10	8"	300	+10-40	16bar	25/02/2021	L22747 L22748	SUS304	FCD400 150LB	SUS304	—	SS400	—	
6	JF150SG	50	3"	300	+10-40	16bar	25/02/2021	L22747 L22748	SUS304	FCD400 PN16	SUS304	—	SS400	—	
7	JF150SG	4	4"	300	+10-40	16bar	25/02/2021	L22747 L22748	SUS304	FCD400 PN16	SUS304	—	SS400	—	
8	JF150SG	60	8"	300	+10-40	16bar	25/02/2021	L22747 L22748	SUS304	FCD400 PN16	SUS304	—	SS400	—	
9	JF250SP	10	3"	13"	+10-40	10K	25/02/2021	L22747 L22748	SUS304	—	SUS304	SS400	—	—	
10	JF250SP	12	4"	13"	+10-40	10K	25/02/2021	L22747 L22748	SUS304	—	SUS304	SS400	—	—	
11	JF250SP	18	5"	13"	+10-40	10K	25/02/2021	L22747 L22748	SUS304	—	SUS304	SS400	—	—	
12	JF250SP	3	6"	13"	+10-40	10K	25/02/2021	L22747 L22748	SUS304	—	SUS304	SS400	—	—	

NOTE : Four Copies For this material Certificate

"DRAWN UNDER HONG LEONG BANK BERHAD,
LC NO: LCPR041694, DATED: 18 FEBRUARY 2021"

Company	Inspector
	
Manager	Inspector
