

YUANDA VALVE GROUP CO., LTD.

TEST REPORT

S-pattern C1 Globe V/V F/E  
PN16

NO: ZPO-2011-0032

PRODUCTION DATE:

ITEM	SIZE(MM)	QTY	DIMENSION(MM)				SHELL TEST				SEAL TEST					
			FACE TO FACE	HOLE CENTER DISTANCE	FLANGE DIAMETER	HOLE NOS*HOLE DIAMETER	MEDIUM	MPa		TEST TIME(Sec)		MEDIUM	MPa		TEST TIME(Sec)	
								STD	TEST	STD	TEST		STD	TEST	STD	TEST
GLOBE VALVE	DN40	120	200	110	150	4*19	WATER	2.4	2.4	15	15	WATER	1.76	1.76	60	60

THROUGH INSPECTION, THE PRODUCTS MEET QUALITY STANDARD, SALES ARE ALLOWED.

INSPECTOR: 

DATE:



QUALITY CONTROL DEPARTMENT

YUANDA VALVE GROUP CO., LTD.

TEST REPORT

NO: ZPO-2011-0032


PRODUCTION DATE:

ITEM	SIZE(MM)	QTY	DIMENSION(MM)				SHELL TEST				SEAL TEST					
			FACE TO FACE	HOLE CENTER DISTANCE	FLANGE DIAMETER	HOLE NOS*HOLE DIAMETER	MEDIUM	MPa	TEST	STD	TEST TIME(Sec)	MEDIUM	MPa	TEST	STD	TEST TIME(Sec)
GLOBE VALVE	DN40	120	200	110	150	4*19	WATER	2.4	2.4	15	15	WATER	1.76	1.76	60	60

THROUGH INSPECTION, THE PRODUCTS MEET QUALITY STANDARD, SALES ARE ALLOWED.

INSPECTOR: BA15

DATE:



QUALITY CONTROL DEPARTMENT