

# YUANDA VALVE GROUP CO., LTD.

## TEST REPORT

NO: ZPO-2009-0041

PRODUCTION DATE:

ITEM	SIZE(MM)	DIMENSION(MM)				SHELL TEST				SEAL TEST					
		FACE TO FACE	HOLE CENTER DISTANCE	FLANGE DIAMETER	HOLE NOS*HOLE DIAMETER	MEDIUM	MPa		TEST TIME(Sec)		MEDIUM	MPa		TEST TIME(Sec)	
							STD	TEST	STD	TEST		STD	TEST	STD	TEST
GLOBE VALVE	DN25	160	85	115	4*14	WATER	2.4	2.4	15	15	WATER	1.76	1.76	60	60
	DN250	730	355	405	12*28	WATER	2.4	2.4	120	120	WATER	1.76	1.76	60	60

THROUGH INSPECTION, THE PRODUCTS MEET QUALITY STANDARD, SALES ARE ALLOWED.

INSPECTOR: 

DATE:



QUALITY CONTROL DEPARTMENT

**YUANDA VALVE GROUP CO.,LTD.**

**MATERIAL TESTING REPORT**

NO: ZPO-2009-0041

PRODUCTION DATE:

NAME	MODEL & SIZE	MATERIALS				CHEMICAL CONSTITUENT (%)				
		BODY	BONNET	DISC	STEM	C	SI	MN	S	P
GLOBE VALVE	DN25	GG25	QT450	2Cr13	2Cr13	3.21	1.83	0.72	0.023	0.053
	DN250	GG25	QT450	A105	2Cr13	3.24	1.85	0.73	0.024	0.054

CONCLUSION: THE ABOVE TESTED PRODUCTS ARE QUALIFIED AND ACCEPTED FOR SALE.

INSPECTOR:  DATE:

