INSPECTION TEST CERTIFICATE

YUHUAN TOP VALVES CO. LTD.

Add: Chumen Industrial Zone,Yuhuan,Zhejiang, China 317605

Tel: 0086-576-87423803 Fax: 0086-576-87423802

INSPECTION CERTIFICATION

TO : Unimech Engineering (M) Sdn.Bhd.

PO NO: ZPO-2006-0009

DESIGN AND MANUFACTURE ACCORDING TO EN13828

CERTIFICATE NO: TP20210730-UM01

DATE: July 30, 2021

NO.	DESCRIPTION	Order QTY	TESTED QTY	RATING	SIZE	MATERIAL				PRESSURE TEST		
										STRENGTH	SEALING	
						BODY	BALL	-	-	BODY	WATER	AIR
1	BRASS CHECK VALVE	1216	2	200Psi	3/4", 2"	Brass	Brass	-	-	400Psi	300Psi	80Psi

NO	BODY NO,	PARTS	HEAT NO.	MATERIAL	Tensile strength	Tensile stretch	Forging temperature	Chemical Specificantion (%)											
								Cu	Pb	Zn	Sn	Fe	Ni	Al	P	Si	Mn	Cr	Bi
1	-	Body	3/4"	Brass	340~380 Mpa	12-15%	680℃~710℃	57.32	2.78	37.79	0.710	0.60	0.332	0.130	0.0042	0.028	0.014	0.010	0.035
2	-	Body	2"	Brass	340~380 Mpa	12-15%	680℃~710℃	57.34	2.66	37.53	0.770	0.69	0.332	0.130	0.0040	0.022	0.013	0.017	0.023

RESULT PASS

We hereby certify that the material described above has been tested and complies with the terms of relevant order contract

INSPECTOR : Mr. Xie Chuanhao

MANAGER/DIRECTOR: Mr Ren Yuqiang

玉环帝格阀门有限公司
YUHUAN TOP VALVES CO.,LTD.

任育强

AUTHORISED SIGNATURE