



ARITA VALVE QUALITY & PRODUCT INSPECTION REPORT

DO NO.	MODEL	TAG NO.	PRESSURE	QTY	NORMINAL DIAMETER	DATE									
DO-2005-0045	CI Sight Glass S/E With Flapper	-	JIS 10K	20 pcs	DN25(1")	20TH.MAY.2020									
PRESSURE TEST															
HYDROSTATIC PRESSURE TEST															
PRESSURE : 1.5 Mpa															
DURATION : 1 MINUTES															
LEAKAGE OK															
RELATIVE STANDARD															
STANDARD BS21 (BSPT)															
MATERIAL CERTIFICATE															
DESCRIPTION	CHEMICAL COMPOSITION (%)						MECHANICAL PROPERTIES								
PART MATERIAL	HEAT NO.	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	V	TENSILE Mpa	YIELD Mpa	ELONGATION %	REDUCE AREA %
Body	FC 200	N/A	3.6	0.3	0.03	0.04	2.6	-	-	-	-	200			
Cap	FC 200	N/A	3.6	0.3	0.03	0.04	2.6	-	-	-	-	200			
REMARK: IN ACCORDANCE WITH EN 10204.3.1B															
HEREBY, WE CERTIFY THAT THE NOMINATED PRODUCTS ARE QUALIFIED AND COMPLIANCE IN:															
1.MAIN COMPONENTS OF NATIONAL STANDARD OR / RELATIVE CRITERION.															
2.CONNECTION SIZE OF NATIONAL STANDARD OR / RELATIVE CRITERION.															
3.QUEST OF CLIENT OR P.O. SPECIFIED															
ARITA VALVE MFG. (M) SDN. BHD.															