


# ZHEJIANG NACHUAN VALVE CO., LTD

## INSPECTION TEST CERTIFICATE

DATE: May 2021

Type	Q. ty	Parts	Material	Heat No.	% Chemical Composition										Mechanical Capacity				
					C	Si	Mn	P	S	Ni	Cr	Mo	Cu	V	$\sigma_b$	$\sigma_s$ Mpa	$\delta$ %	$\psi$ %	HB
Check Valve 150LB- 3"	12	体盖	WCB	N1080	0.023	0.54	0.85	0.032	0.04	0.33	0.44	0.11	/	/	494	252	34	26	/
PRESSURE TEST																			
Test		Shell ( Mpa)		Seal ( Mpa)		Back Seat (Mpa)		Gas Test (Mpa)		Material Acc: ASTM A216									
Medium	Water	3.0		2.1		-		-		Test Acc: API598									
	Gas	-		-		-		-		Note:Applicable medium Medium: Water, Gas, Oil, Sour, etc.									
Duration (S)		60		60		-		-											
Result		Qualified		Qualified		Qualified		Qualified											



Inspectors: 王庆祝