

UNIMECH (SHANGHAI) Co., LTD

Mill Certification


Purchaser: UNIMECH ENGINEERING(M)SDN.BHD

Product Name	Model	Size (MM)	ANSI	Applicable Temp	Medium	Quantity	Note
Y-STRAINER	Y41W-150	DN50; DN65; DN100	ANSI150	150°C	Petroleum Gas	1000	
NO.							

TEST RECORD

PRESSURE TEST				Appearance inspection		Conclusion	
Shell Test	Back seal test	Low pressure test	High pressure test	Cleanliness inspection	Inspection items	SheetNO.	Conclusion
Pressure:3.00 Mpa Medium: Water Time:120S	Pressure:/Mpa Medium: Water Time:120S	Pressure:0.62Mpa Medium: Water Time:120S	Pressure:2.20Mpa Medium: Water Time:120S	Level A Level B Level C			
Test & inspection to:	<input type="checkbox"/> SH3406	<input type="checkbox"/> HG20635-97	<input type="checkbox"/> AP1598	<input type="checkbox"/> AP16D	<input type="checkbox"/> JIS	<input type="checkbox"/> B2020	

MATERIAL		CHEMICAL COMPOSITION						MECHANICAL PROPERTIES									
Part Name	Heat NO.	Original Sheet NO.	Material	C	Mn	Si	S	P	Cr	Ni	Mo	V	Ds Mpa	Ds Mpa	W %	KJ/ m ²	HB
Body			WCB	0.076	1.49	1.97	0.038	0.039	18.02	8.02	/	/	485	264	23		



Through inspecting: testing and confirmability all products above have been inspected and tested in accordance with the applicable specifications drawings and requirements of orders

Test & Inspection Li qi xin	Mechanical & Chemical Analysis Zhang Chao	Received By Cheng Xue Sheng	Signature
-----------------------------	--	--------------------------------	-----------