ZHEJIANG LONZE VALVE CO.,LTD
FIVE-STAR INDUSTRIAL ZONE,OUBEI,WENZHOU,CHINA

INSPECTION CERTIFICATION
TO

P-O: ZPO-2009-0037
CERTIFICATE NO: LONZ2020093007
Date:May.4th,2021

DESIGN AND MANUFACTURE ACCORDING TO API 602 & API 598

| PAGE NO. | | QTY (PCS) | DESCRIPTION | | RATING | connection | SIZE | MATERIAL | | | | | | | | PRESSURE TEST | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | BODY/CAP | | SEAT | | DISC | | STEM | | STRENGTH | | SEALING | |
| | | | | | | | | | | | | | | | | BODY | | WATER | AIR |
| 1 | | 8 | forged lift check valve | | 150# | RF | 1" | A105 | | A276 410 | | A276 410+STL | | / | | 3 | | 2.2 | / |
| | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | |
| NO | BODY NO, | PARTS | HEAT NO. | MATERIAL | YIELD POINT (MPa) | TENSILE STRENGTH (MPa) | ELONG-ATION (%) | RED OF AREA (%) | HB | C | Si | Mn | P | S | Cr | Ni | Mo | Cu | N |
| 1 | - | BODY | - | A105 | 280 | 525 | 28 | 40 | 153 | 0.211 | 0.240 | 0.910 | 0.027 | 0.011 | 0.126 | 0.026 | 0.015 | 0.021 | 0.001 |
| | | BONNET | - | A105 | 280 | 525 | 28 | 40 | 153 | 0.211 | 0.240 | 0.910 | 0.027 | 0.011 | 0.126 | 0.026 | 0.015 | 0.021 | 0.001 |
| | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | |
| RESULT | | | | | | ACCEPTABLE | | | | | | | | | | | | | |

We hereby certify that the material described above has been tested and complies with the terms of relevant order contract

INSPECTOR : WANG XIAYUN

AUTHORISED SIGNATURE

浙江隆成阀门有限公司
ZHEJIANG LONZE VALVE CO.,LTD

余成连