TEST CERTIFICATE

MESSRS:UNIMECH ENGINEERING (M) SDN. BHD.

ORDER NO:

DATE: JULY .10,2017

NO.	DESCRIPTION OF ITEM	QTY (PCS)	HYDROSLATIC TEST		PNEUMATIC TEST		MAIN DIMENSION	REMARKS
			SHELL BAR	SEAT BAR	SHELL BAR	SEAT BAR		
	ARITA BRAND CI SWING CHECK VALVE F/E TO T/E							
	3″	30	15	11			**GOOD**	**NO LEAK**
	6″	30	15	11			**GOOD**	**NO LEAK**
	12″	8	15	11			**GOOD**	**NO LEAK**
	BLANK							
MATERIAL:BODY,BONNET---CAST IRON(HT200),DISC---CAST IRON(HT200)								

WE CERTIFY THAT THE ABOVE PRODUCTS PASS OUR INSPECTION WITH SATISFACTORY RES

CHIEF OF Q.A. SECTION:XU GONG

Q.A.DEPARTMENT MANAGER:WANG ZHENG HUAN

R.S.VALVE CO.,LTD

P.C.M.
R.S. VALVE CO., LTD.