

# ZHEJIANG ANIX VALVE TECHNOLOGY CO.,LTD

LONGWAN INDUSTRIAL BASE LONGWAN WENZHOU ,(Area 3, Valves Base) CHINA

Mill Test Certificate

Report No.:AN-2106016

Date:June 22nd 2021

Order No.:AN-M-2021-0622

TO:Unimech Engineering (M) Sdn Bhd


## 1. Chemical And Tensile Requirements

Material: ASTM A216 WCB		Chemical Composition %										Tension Test						
Description	Size	Heat NO.	QTY (PCS)	C	Mn	Si	P	S	Cr	Ni	Mo	Cu	V	Nb	Yield Strength ≥250Mpa	Tensile Strength ≥485Mpa	Elongation ≥22%	Contraction Percentage ≥35%
3PC Ball Valve 1000PSI BW R-PTFE	2"	M10432	100	≤0.30	≤1.00	≤0.60	≤0.04	≤0.045	≤0.50	≤0.50	≤0.20	≤0.30	≤0.03	-	262	524	38	48

## 2. Pressure Test And The Results

Detection Project	Media	Measured Values (Mpa)	Duration (s)	Test Results	Results
Shell Test	Water	10.4MPa	≥60	No Leak	Qualified
Seal Test	Air	0.6MPa	≥60	No Leak	Qualified
Test Standard	API 598 (valve inspections and tests )				

We certify that the material has been sampled, tested, and inspected with provisions of the above referenced.



Q.C. Manager: Youcheng Xu