



ARITA VALVE QUALITY & PRODUCT INSPECTION REPORT

MODEL	MODEL NO.	PRESSURE	QTY	NORMINAL DIAMETER	DATE												
ARITA CI Ball Valve F/E C/W Handle	ARV-800FE(J)	JIS 10K	16 pcs	DN150(6")	14TH.DEC.2021												
PRESSURE TEST																	
HYDROSTATIC SHELL TEST	HYDROSTATIC SEAT TEST																
PRESSURE : 1.5 Mpa	PRESSURE : 1.1 Mpa																
DURATION : 1 MINUTES	DURATION : 1 MINUTES																
LEAKAGE OK	LEAKAGE OK																
RELATIVE STANDARD																	
STANDARD	JIS 10K																
MATERIAL CERTIFICATE																	
DESCRIPTION	CHEMICAL COMPOSITION (%)						MECHANICAL PROPERTIES										
	PART MATERIAL	HEAT NO.	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	V	Other	Tensile Mpa	Yield Mpa	ELONGATION %	REDUCE AREA%
Body	FC 200	N/A	3.2	0.4	0.02	0.04	2.4							210		-	
Stem	SUS 410	N/A	0.1	0.17	0.02	0.01	0.59	-	0.1	11.76	-	-		745			
REMARK: IN ACCORDANCE WITH EN 10204.3.1B																	
HEREBY, WE CERTIFY THAT THE NOMINATED PRODUCTS ARE QUALIFIED AND COMPLIANCE IN:																	
1. MAIN COMPONENTS OF NATIONAL STANDARD OR / RELATIVE CRITERION.																	
2. CONNECTION SIZE OF NATIONAL STANDARD OR / RELATIVE CRITERION.																	
3. QUEST OF CLIENT OR P.O. SPECIFIED																	
ARITA VALVE MFG. (M) SDN. BHD.																	



ARITA VALVE QUALITY & PRODUCT INSPECTION REPORT

MODEL	MODEL NO.	PRESSURE	QTY	NORMINAL DIAMETER	DATE
ARITA CI Ball Valve F/E C/W Handle	ARV-800FE(J)	JIS 10K	3 pcs	DN80(3")	14TH.DEC.2021

PRESSURE TEST	
HYDROSTATIC SHELL TEST	HYDROSTATIC SEAT TEST
PRESSURE : 1.5 Mpa	PRESSURE : 1.1 Mpa
DURATION : 1 MINUTES	DURATION : 1 MINUTES
LEAKAGE OK	LEAKAGE OK

RELATIVE STANDARD	
STANDARD	JIS 10K

MATERIAL CERTIFICATE																
DESCRIPTION	CHEMICAL COMPOSITION (%)															
PART MATERIAL	HEAT NO.	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	V	Other	Tensile Mpa	Yield Mpa	ELONGATION %	REDUCE AREA%
Body	FC 200	N/A	3.2	0.4	0.02	0.04	2.4						210			-
Stem	SUS 410	N/A	0.1	0.17	0.02	0.01	0.59	-	0.1	11.76	-	-	745			


REMARK: IN ACCORDANCE WITH EN 10204.3.1B

HEREBY, WE CERTIFY THAT THE NOMINATED PRODUCTS ARE QUALITIED AND COMPLIANCE IN:

1.MAIN COMPONENTS OF NATIONAL STANDARD OR / RELATIVE CRITERION.

2.CONNECTION SIZE OF NATIONAL STANDARD OR / RELATIVE CRITERION.

3.QUEST OF CLIENT OR P.O. SPECIFIED



ARITA VALVE MFG. (M) SDN. BHD.

ARITA VALVE MFG. (M) SDN. BHD.