



ARITA VALVE QUALITY & PRODUCT INSPECTION REPORT

D/O NO.	MODEL	MODEL NO.	PRESSURE	QTY	NORMINAL DIAMETER	DATE
DO-2112-0083	ARITA CI Y-Strainer F/E	ARF-805FE(A)	ANSI 150LB	4 pcs	DN40(1-1/2")	27TH.DEC.2021

PRESSURE TEST

HYDROSTATIC PRESSURE TEST	
PRESSURE : 15.0 Bar	
DURATION : 2 MINUTES	
LEAKAGE OK	

RELATIVE STANDARD

STANDARD	ANSI B16.1
----------	------------

MATERIAL CERTIFICATE

DESCRIPTION	CHEMICAL COMPOSITION (%)										MECHANICAL PROPERTIES					
	HEAT NO.	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	V	Other	TENSILE Mpa	YIELD Mpa	ELONGATION %	REDUCE AREA %
Body	FC 200	N/A	3.3	0.6	0.02	0.03	2.4	-	-	-	-	-	210	-	-	-
Screen	SUS 304	A5800-3010	0.05	1.2	0.03	-	0.46	-	8.28	18.3	-	-	658	-	-	-


REMARK: IN ACCORDANCE WITH EN 10204.3.1B

HEREBY, WE CERTIFY THAT THE NOMINATED PRODUCTS ARE QUALITIED AND COMPLIANCE IN:

1.MAIN COMPONENTS OF NATIONAL STANDARD OR / RELATIVE CRITERION.

2.CONNECTION SIZE OF NATIONAL STANDARD OR / RELATIVE CRITERION.

3.QUEST OF CLIENT OR P.O. SPECIFIED



ARITA VALVE MFG. (M) SDN. BHD.



ARITA VALVE QUALITY & PRODUCT INSPECTION REPORT

D/O NO.	MODEL	MODEL NO.	PRESSURE	QTY	NORMINAL DIAMETER	DATE
DO-2112-0093	ARITA CI Y-Strainer F/E	ARF-805FE(A)	ANSI 150LB	34 pcs	DN65(2-1/2")	27TH.DEC.2021

PRESSURE TEST

HYDROSTATIC PRESSURE TEST	
PRESSURE : 15.0 Bar	
DURATION : 2 MINUTES	
LEAKAGE	OK

RELATIVE STANDARD

STANDARD	ANSI B16.1
----------	------------

MATERIAL CERTIFICATE

DESCRIPTION	CHEMICAL COMPOSITION (%)											MECHANICAL PROPERTIES						
	Part	Material	Heat No.	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	V	Other	Tensile Mpa	Yield Mpa	Elongation %	Reduce Area %
Body	FC 200	N/A	3.3	0.6	0.02	0.03	2.4	-	-	-	-	-	-	-	210	-	-	-
Screen	SUS 304	A5800-3010	0.05	1.2	0.03	-	0.46	-	8.28	18.3	-	-	-	-	658	-	-	-


REMARK: IN ACCORDANCE WITH EN 10204.3.1B

HEREBY, WE CERTIFY THAT THE NOMINATED PRODUCTS ARE QUALIFIED AND COMPLIANCE IN:


1. MAIN COMPONENTS OF NATIONAL STANDARD OR / RELATIVE CRITERION.

2. CONNECTION SIZE OF NATIONAL STANDARD OR / RELATIVE CRITERION.

3. QUOTATION OF CLIENT OR P.O. SPECIFIED



ARITA VALVE MFG. (M) SDN. BHD.



ARITA VALVE QUALITY & PRODUCT INSPECTION REPORT

D/O NO.	MODEL	MODEL NO.	PRESSURE	QTY	NORMINAL DIAMETER	DATE
DO-2112-0083	ARITA CI Y-Strainer F/E	ARF-805FE(A)	ANSI 150LB	12 pcs	DN80(3")	27TH.DEC.2021

PRESSURE TEST

HYDROSTATIC PRESSURE TEST	
PRESSURE : 15.0 Bar	
DURATION : 2 MINUTES	
LEAKAGE	OK

RELATIVE STANDARD

STANDARD	ANSI B16.1
----------	------------

MATERIAL CERTIFICATE

DESCRIPTION	CHEMICAL COMPOSITION (%)										MECHANICAL PROPERTIES							
	Part	Material	Heat No.	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	V	Other	Tensile Mpa	Yield Mpa	Elongation %	Reduce Area %
Body	FC 200	N/A	3.3	0.6	0.02	0.03	2.4	-	-	-	-	-	-	-	210	-	-	-
Screen	SUS 304	A.5800-3010	0.05	1.2	0.03	-	0.46	-	8.28	18.3	-	-	-	-	658	-	-	-


REMARK: IN ACCORDANCE WITH EN 10204.3.1B

HEREBY, WE CERTIFY THAT THE NOMINATED PRODUCTS ARE QUALIFIED AND COMPLIANCE IN:


1. MAIN COMPONENTS OF NATIONAL STANDARD OR / RELATIVE CRITERION.

2. CONNECTION SIZE OF NATIONAL STANDARD OR / RELATIVE CRITERION.

3. QUEST OF CLIENT OR P.O. SPECIFIED



ARITA VALVE MFG. (M) SDN. BHD.



ARITA VALVE QUALITY & PRODUCT INSPECTION REPORT

D/O NO.	MODEL	MODEL NO.	PRESSURE	QTY	NORMINAL DIAMETER	DATE
DO-2112-0083	ARITA CI Y-Strainer F/E	ARF-805FE(A)	ANSI 150LB	1 pc	DN125 (5")	27TH.DEC.2021

PRESSURE TEST

HYDROSTATIC PRESSURE TEST	
PRESSURE : 15.0 Bar	
DURATION : 2 MINUTES	
LEAKAGE	OK

RELATIVE STANDARD

STANDARD	ANSI B16.1
----------	------------

MATERIAL CERTIFICATE

DESCRIPTION	CHEMICAL COMPOSITION (%)										MECHANICAL PROPERTIES					
	HEAT NO.	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	V	Other	TENSILE Mpa	YIELD Mpa	ELONGATION %	REDUCE AREA %
Body	FC 200	N/A	3.3	0.6	0.02	0.03	2.4	-	-	-	-	-	210	-	-	-
Screen	SUS 304	A.5800-3010	0.05	1.2	0.03	-	0.46	-	8.28	18.3	-	-	658	-	-	-

REMARK: IN ACCORDANCE WITH EN 10204.3.1B

HEREBY, WE CERTIFY THAT THE NOMINATED PRODUCTS ARE QUALIFIED AND COMPLIANCE IN:

1.MAIN COMPONENTS OF NATIONAL STANDARD OR / RELATIVE CRITERION.

2.CONNECTION SIZE OF NATIONAL STANDARD OR / RELATIVE CRITERION.

3.QUEST OF CLIENT OR P.O. SPECIFIED

ARITA VALVE MFG. (M) SDN. BHD.

