



ARITA VALVE QUALITY & PRODUCT INSPECTION REPORT

| | | | | | | |
|--------------|-------------------------|--------------|----------|-------|-------------------|---------------|
| D/O NO. | MODEL | MODEL NO. | PRESSURE | QTY | NORMINAL DIAMETER | DATE |
| DO-2112-0067 | ARITA CI Y-Strainer F/E | ARF-805FE(A) | PN16 | 5 pcs | DN65(2-1/2") | 27TH.DEC.2021 |

PRESSURE TEST

| | |
|---------------------------|----|
| HYDROSTATIC PRESSURE TEST | |
| PRESSURE : 15.0 Bar | |
| DURATION : 2 MINUTES | |
| LEAKAGE | OK |

RELATIVE STANDARD

| | |
|----------|-----------|
| STANDARD | BS EN1092 |
|----------|-----------|

MATERIAL CERTIFICATE

| DESCRIPTION | CHEMICAL COMPOSITION (%) | | | | | | | | | | MECHANICAL PROPERTIES | | | | | |
|-------------|--------------------------|------------|------|-----|------|------|------|----|------|------|-----------------------|-------|-------------|-----------|--------------|---------------|
| | HEAT NO. | C | Mn | P | S | Si | Cu | Ni | Cr | Mo | V | Other | TENSILE Mpa | YIELD Mpa | ELONGATION % | REDUCE AREA % |
| Body | FC 200 | N/A | 3.3 | 0.6 | 0.02 | 0.03 | 2.4 | - | - | - | - | - | 210 | - | - | - |
| Screen | SUS 304 | A5800-3010 | 0.05 | 1.2 | 0.03 | - | 0.46 | - | 8.28 | 18.3 | - | - | 658 | - | - | - |


REMARK: IN ACCORDANCE WITH EN 10204.3.1B

HEREBY, WE CERTIFY THAT THE NOMINATED PRODUCTS ARE QUALIFIED AND COMPLIANCE IN:

1. MAIN COMPONENTS OF NATIONAL STANDARD OR / RELATIVE CRITERION.

2. CONNECTION SIZE OF NATIONAL STANDARD OR / RELATIVE CRITERION.

3. QUEST OF CLIENT OR P.O. SPECIFIED



ARITA VALVE MFG. (M) SDN. BHD.