INSPECTION TEST CERTIFICATE

ZHEJIANG LONZE VALVE CO.,LTD
FIVE-STAR INDUSTRIAL ZONE,OUBEI,WENZHOU,CHINA

INSPECTION CERTIFICATION
TO

P-O:
CERTIFICATE NO: LONZ2021041903
Date:Mar.4th,2022

DESIGN AND MANUFACTURE ACCORDING TO API 602 & API 598

PAGE NO.	QTY (PCS)	DESCRIPTION	RATING	connection	SIZE	MATERIAL				PRESSURE TEST		
										STRENGTH	SEALING	
						BODY/CAP	SEAT	DISC	STEM	BODY	WATER	AIR
1	5	CS BELLOW SEAL GLOBE VALVE	PN16	RF	DN65	GS-C25	int+13Cr	A105	20Cr13	2.4	1.76	0.6

NO	BODY NO,	PARTS	HEAT NO.	MATERIAL	YIELD POINT (MPa)	TENSILE STRENGTH (MPa)	ELONG-ATION (%)	RED OF AREA (%)	HB	C	Si	Mn	P	S	Cr	Ni	Mo	Cu	V
1	-	BODY	-	GS-C25	275	526	28	40	153	0.201	0.413	0.712	0.032	0.011	0.036	0.031	0.018	0.021	0.001
		BONNET	-	GS-C25	275	526	28	40	153	0.201	0.413	0.712	0.032	0.011	0.036	0.031	0.018	0.021	0.001
RESULT						ACCEPTABLE													

We hereby certify that the material described above has been tested and complies with the terms of relevant order contract

INSPECTOR : WANG XIAYUA

AUTHORISED SIGNATURE

浙江隆成阀门有限公司
ZHEJIANG LONZE VALVE CO.,LTD

余成達