



ARITA VALVE QUALITY & PRODUCT INSPECTION REPORT

D/O NO.	MODEL	MODEL NO.	PRESSURE	QTY	NORMINAL DIAMETER	DATE
DO-2202-0013	SUS 316 3-Pc Disco Check Valve	ARV-106SE(U)-3Pc	PN 40	10 pcs	DN20 (3/4")	9TH.FEBRUARY.2022

PRESSURE TEST	
HYDROSTATIC TEST FOR SHELL	HYDROSTATIC LEAKAGE TEST
PRESSURE : 60 Bar	PRESSURE : 44 Bar
DURATION : 1 MINUTES	DURATION : 1 MINUTES
LEAKAGE OK	LEAKAGE OK

STANDARD	DIN 3202-3 K4	RELATIVE STANDARD
----------	---------------	-------------------

MATERIAL CERTIFICATE																
CHEMICAL COMPOSITION (%)																
DESCRIPTION																
PART	MATERIAL	HEAT NO.	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	V	TENSILE Mpa	YIELD Mpa	ELONGATION %	REDUCE AREA%
Body	CF8M	-	0.02	1.13	0.03	0.002	0.35	-	10.1	18.0	2.2	-				
Disc	CF8M	-	0.02	0.67	0.03	0.006	0.65	-	10.1	18.7	2.1	-				

REMARK: IN ACCORDANCE WITH EN 10204.3.1B


HEREBY, WE CERTIFY THAT THE NOMINATED PRODUCTS ARE QUALIFIED AND COMPLIANCE IN:

1.MAIN COMPONENTS OF NATIONAL STANDARD OR / RELATIVE CRITERION.

2.CONNECTION SIZE OF NATIONAL STANDARD OR / RELATIVE CRITERION.

3.QUEST OF CLIENT OR P.O. SPECIFIED


ARITA VALVE MFG. (M) SDN. BHD.





ARITA VALVE QUALITY & PRODUCT INSPECTION REPORT

D/O NO.	MODEL	MODEL NO.	PRESSURE	QTY	NORMINAL DIAMETER	DATE									
DO-2202-0013	SUS 316 3-Pc Disco Check Valve	ARV-106SE(U)-3Pc	PN 40	10 pcs	DN40 (1-1/2")	9TH.FEBRUARY.2022									
PRESSURE TEST															
HYDROSTATIC TEST FOR SHELL															
HYDROSTATIC LEAKAGE TEST															
PRESSURE : 60 Bar															
PRESSURE : 44 Bar															
DURATION : 1 MINUTES															
DURATION : 1 MINUTES															
LEAKAGE OK															
LEAKAGE OK															
RELATIVE STANDARD															
STANDARD															
DIN 3202-3 K4															
MATERIAL CERTIFICATE															
CHEMICAL COMPOSITION (%)															
DESCRIPTION	HEAT NO.	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	V	TENSILE Mpa	YIELD Mpa	ELONGATION %	REDUCE AREA%
Body	-	0.02	1.13	0.03	0.002	0.35	-	10.1	18.0	2.2	-				
Disc	-	0.02	0.67	0.03	0.006	0.65	-	10.1	18.7	2.1	-				
REMARK: IN ACCORDANCE WITH EN 10204.3.1B															
HEREBY, WE CERTIFY THAT THE NOMINATED PRODUCTS ARE QUALIFIED AND COMPLIANCE IN:															
1.MAIN COMPONENTS OF NATIONAL STANDARD OR / RELATIVE CRITERION.															
2.CONNECTION SIZE OF NATIONAL STANDARD OR / RELATIVE CRITERION.															
3.QUEST OF CLIENT OR P.O. SPECIFIED															



ARITA VALVE MFG. (M) SDN. BHD.