



ARITA VALVE QUALITY & PRODUCT INSPECTION REPORT

D/O NO.	MODEL	MODEL NO.	PRESSURE	QTY	NORMINAL DIAMETER	DATE
DO-2202-0013	SUS 316 Disco Check Valve	ARV-106WT(U)	PN 40	10 pcs	DN100 (4")	9TH.FEBRUARY.2022

PRESSURE TEST	
HYDROSTATIC TEST FOR SHELL	HYDROSTATIC LEAKAGE TEST
PRESSURE : 60 Bar	PRESSURE : 44 Bar
DURATION : 1 MINUTES	DURATION : 1 MINUTES
LEAKAGE OK	LEAKAGE OK

RELATIVE STANDARD	
STANDARD	DIN 3202-3 K4

MATERIAL CERTIFICATE															
CHEMICAL COMPOSITION (%)															
DESCRIPTION	HEAT NO.	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	V	TENSILE Mpa	YIELD Mpa	ELONGATION %	REDUCE AREA%
Body	-	0.02	1.13	0.03	0.002	0.35	-	10.1	18.0	2.2	-				
Disc	-	0.02	0.67	0.03	0.006	0.65	-	10.1	18.7	2.1	-				


REMARK: IN ACCORDANCE WITH EN 10204.3.1B

HEREBY, WE CERTIFY THAT THE NOMINATED PRODUCTS ARE QUALITIED AND COMPLIANCE IN:

1.MAIN COMPONENTS OF NATIONAL STANDARD OR / RELATIVE CRITERION.


2.CONNECTION SIZE OF NATIONAL STANDARD OR / RELATIVE CRITERION.

3.QUEST OF CLIENT OR P.O. SPECIFIED



(Signature)

ARITA VALVE MFG. (M) SDN. BHD.




ARITA VALVE QUALITY & PRODUCT INSPECTION REPORT

D/O NO.	MODEL	MODEL NO.	PRESSURE	QTY	NORMINAL DIAMETER	DATE									
DO-2202-0013	SUS 316 Disco Check Valve	ARV-106WT(U)	PN 40	12 pcs	DN150 (6")	9TH.FEBRUARY.2022									
PRESSURE TEST															
HYDROSTATIC TEST FOR SHELL		HYDROSTATIC LEAKAGE TEST													
PRESSURE : 60 Bar		PRESSURE : 44 Bar													
DURATION : 1 MINUTES		DURATION : 1 MINUTES													
LEAKAGE OK		LEAKAGE OK													
RELATIVE STANDARD															
STANDARD	DIN 3202-3 K4														
MATERIAL CERTIFICATE															
CHEMICAL COMPOSITION (%)															
DESCRIPTION	HEAT NO.	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	V	TENSILE Mpa	YIELD Mpa	ELONGATION %	REDUCE AREA%
Body	-	0.02	1.13	0.03	0.002	0.35	-	10.1	18.0	2.2	-				
Disc	-	0.02	0.67	0.03	0.006	0.65	-	10.1	18.7	2.1	-				
REMARK: IN ACCORDANCE WITH EN 10204.3.1B															
HEREBY, WE CERTIFY THAT THE NOMINATED PRODUCTS ARE QUALIFIED AND COMPLIANCE IN:															
1.MAIN COMPONENTS OF NATIONAL STANDARD OR / RELATIVE CRITERION.															
2.CONNECTION SIZE OF NATIONAL STANDARD OR / RELATIVE CRITERION.															
3.QUEST OF CLIENT OR P.O. SPECIFIED															
ARITA VALVE MFG. (M) SDN. BHD.															



ARITA VALVE QUALITY & PRODUCT INSPECTION REPORT

D/O NO.	MODEL	MODEL NO.	PRESSURE	QTY	NORMINAL DIAMETER	DATE										
DO-2202-0013	SUS 316 Disco Check Valve	ARV-106WT(U)	PN 40	12 pcs	DN200 (8")	9TH.FEBRUARY.2022										
PRESSURE TEST																
HYDROSTATIC TEST FOR SHELL		HYDROSTATIC LEAKAGE TEST														
PRESSURE : 60 Bar		PRESSURE : 44 Bar														
DURATION : 1 MINUTES		DURATION : 1 MINUTES														
LEAKAGE OK		LEAKAGE OK														
RELATIVE STANDARD																
STANDARD	DIN 3202-3 K4															
MATERIAL CERTIFICATE																
DESCRIPTION	CHEMICAL COMPOSITION (%)															
PART	MATERIAL	HEAT NO.	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	V	TENSILE Mpa	YIELD Mpa	ELONGATION %	REDUCE AREA%
Body	CF8M	-	0.02	1.13	0.03	0.002	0.35	-	10.1	18.0	2.2	-				
Disc	CF8M	-	0.02	0.67	0.03	0.006	0.65	-	10.1	18.7	2.1	-				
REMARK: IN ACCORDANCE WITH EN 10204.3.1B																
HEREBY, WE CERTIFY THAT THE NOMINATED PRODUCTS ARE QUALIFIED AND COMPLIANCE IN:																
1.MAIN COMPONENTS OF NATIONAL STANDARD OR / RELATIVE CRITERION.																
2.CONNECTION SIZE OF NATIONAL STANDARD OR / RELATIVE CRITERION.																
3.QUEST OF CLIENT OR P.O. SPECIFIED																



ARITA VALVE MFG. (M) SDN. BHD.