



YUANDA VALVE GROUP CO.,LTD TESTING REPORT

INV.NO:

PRODUCT NAME	SIZE (MM)	QTY	CONNECTION DIMENSION				SHELL TESTING				SEAL TESTING					
			FACE TO FACE (mm)	CENTER DISTANCE BETWEEN HOLES (mm)	FLANGE DIMENSION (mm)	HOLE *DIAMETER	MEDIUM	PRESSURE TESTING (Mpa)		PRESSURE KEEPING TIME(Sec)		MEDIUM	PRESSURE TESTING (Mpa)		PRESSURE KEEPING TIME(Sec)	
								STD	ACT	STD	ACT		STD	ACT	STD	ACT
DIN GLOBE VALVE	J41H-16-50	1	230	125	165	4*19	WATER	2.4	2.4	15	15	WATER	1.76	1.76	60	60
DIN GLOBE VALVE	J41H-16-125	1	400	210	250	8*19	WATER	2.4	2.4	60	60	WATER	1.76	1.76	60	60

AFTER TESTING VALVES,THE PRODUCTS ARE GOOD AND ALLOWED TO DELIVERY.

CHECKER:

DATE: 2022.6.9

QUALITY CONTROL DE





YUANDA VALVE GROUP CO.,LTD

MATERIAL REPORT

INV.NO:ZPO-2110-0011

PRODUCT NAME	SIZE(mm)	Q'TY	MATERIAL				CHEMICAL ANALYSIS (%)				
			BODY	COVER	DISC	STEM	C	Si	Mn	P	S
							3.1-3.5%	1.7-2.2%	0.7-1.2%	≤0.12	≤0.12
GLOBE VALVE	J41H-16-50	1	GG25	QT450	2Cr13	2Cr13	3.22	1.81	0.77	0.021	0.051
GLOBE VALVE	J41H-16-125	1	GG25	QT450	A105	2Cr13	3.25	1.86	0.74	0.025	0.055

AFTER TESTING VALVES,THE PRODUCTS ARE GOOD AND ALLOWED TO DELIVERY.

CHECKER:

DATE: 2022.6.9

QUALITY CONTROL DEPT:

