





ARITA VALVE QUALITY & PRODUCT INSPECTION REPORT

P/O NO	MODEL	MODEL NO	PRESSURE	QTY	NORMINAL DIAMETER	DATE											
APO-2203-0090	ARITA CI Ball Valve F/E C/W Handle	ARV-800FE(J)-S	10K	20 pcs	DN150 (6")	15TH.MARCH.2022											
PRESSURE TEST																	
HYDROSTATIC SHELL TEST		HYDROSTATIC SEAT TEST															
PRESSURE : 1.5 Mpa		PRESSURE : 1.1 Mpa															
DURATION : 2 MINUTES		DURATION : 2 MINUTES															
LEAKAGE OK		LEAKAGE OK															
RELATIVE STANDARD																	
STANDARD	JIS 10K																
MATERIAL CERTIFICATE																	
DESCRIPTION	CHEMICAL COMPOSITION (%)					MECHANICAL PROPERTIES											
PART	MATERIAL	HEAT NO.	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	V	Other	Tensile Mpa	Yield Mpa	ELONGATION %	REDUCE AREA%
Body	FC 200	N/A	3.1	0.6	0.02	0.02	2.4							205			
Stem	SUS 410	N/A	0.1	0.32	0.03	0.01	0.51	-	0.3	12.05	-	-	-	745		-	
REMARK: IN ACCORDANCE WITH EN 10204.3.1B																	
HEREBY, WE CERTIFY THAT THE NOMINATED PRODUCTS ARE QUALITIED AND COMPLIANCE IN:																	
1.MAIN COMPONENTS OF NATIONAL STANDARD OR / RELATIVE CRITERION.																	
2.CONNECTION SIZE OF NATIONAL STANDARD OR / RELATIVE CRITERION.																	
3.QUEST OF CLIENT OR P.O. SPECIFIED																	
						 											
ARITA VALVE MFG. (M) SDN. BHD.																	