




ARITA VALVE QUALITY & PRODUCT INSPECTION REPORT

P/O NO.	MODEL	MODEL NO	PRESSURE	QTY	NORMINAL DIAMETER	DATE											
APO-2203-0090	ARITA CI Y-Strainer S/E BSPT	ARF-805SE	16K	20 pcs	DN25 (1")	15th.March.2022											
PRESSURE TEST																	
HYDROSTATIC PRESSURE TEST																	
PRESSURE : 1.5 Mpa																	
DURATION : 1 MINUTES																	
LEAKAGE OK																	
RELATIVE STANDARD																	
STANDARD	BS 21:1985(BSPT)																
MATERIAL CERTIFICATE																	
DESCRIPTION	CHEMICAL COMPOSITION (%)						MECHANICAL PROPERTIES										
	PART	MATERIAL	HEAT NO.	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	V	TENSILE Mpa	YIELD Mpa	ELONGATION %	REDUCE AREA %
Body	FC 200	N/A	3.6	0.7	0.04	0.06	2.1	-	0.01	0.02	0.02	-	-	208	-	-	-
Cap	FC 200	N/A	3.6	0.7	0.04	0.06	2.1	-	0.01	0.02	0.02	-	-	208	-	-	-
Screen	SUS 304	N/A	0.05	1.2	0.03	-	0.46	-	8.28	18.3	-	-	-	658	-	-	-
REMARK: IN ACCORDANCE WITH EN 10204.3.1B																	
HEREBY, WE CERTIFY THAT THE NOMINATED PRODUCTS ARE QUALIFIED AND COMPLIANCE IN:																	
1.MAIN COMPONENTS OF NATIONAL STANDARD OR / RELATIVE CRITERION.																	
2.CONNECTION SIZE OF NATIONAL STANDARD OR / RELATIVE CRITERION.																	
3.QUEST OF CLIENT OR P.O. SPECIFIED																	



ARITA VALVE MFG. (M) SDN. BHD.



ARITA VALVE QUALITY & PRODUCT INSPECTION REPORT

P/O NO.	MODEL	MODEL NO	PRESSURE	QTY	NORMINAL DIAMETER	DATE
APO-2203-0090	ARITA CI Y-Strainer S/E BSPT	ARF-805SE	16K	10 pcs	DN32 (1-1/4")	15th.March.2022
PRESSURE TEST						

HYDROSTATIC PRESSURE TEST	
PRESSURE : 1.5 Mpa	
DURATION : 1 MINUTES	
LEAKAGE	OK


RELATIVE STANDARD	
STANDARD	BS 21:1985(BSPT)

DESCRIPTION	CHEMICAL COMPOSITION (%)										MECHANICAL PROPERTIES				
	HEAT NO.	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	V	TENSILE Mpa	YIELD Mpa	ELONGATION %	REDUCE AREA %
Body	FC 200	N/A	3.6	0.7	0.04	0.06	2.1	-	0.01	0.02	-	208	-	-	-
Cap	FC 200	N/A	3.6	0.7	0.04	0.06	2.1	-	0.01	0.02	-	208	-	-	-
Screen	SUS 304	N/A	0.05	1.2	0.03	-	0.46	-	8.28	18.3	-	-	658	-	-

REMARK: IN ACCORDANCE WITH EN 10204.3.1B

HEREBY, WE CERTIFY THAT THE NOMINATED PRODUCTS ARE QUALIFIED AND COMPLIANCE IN:

- 1.MAIN COMPONENTS OF NATIONAL STANDARD OR / RELATIVE CRITERION.
- 2.CONNECTION SIZE OF NATIONAL STANDARD OR / RELATIVE CRITERION.
- 3.QUEST OF CLIENT OR P.O. SPECIFIED



ARITA VALVE MFG. (M) SDN. BHD.



ARITA VALVE QUALITY & PRODUCT INSPECTION REPORT

P/O NO.	MODEL	MODEL NO	PRESSURE	QTY	NORMINAL DIAMETER	DATE
APO-2203-0090	ARITA CI Y-Strainer S/E BSPT	ARF-805SE	16K	10 pcs	DN50 (2")	15th.March.2022

PRESSURE TEST						
HYDROSTATIC PRESSURE TEST						
PRESSURE : 1.5 Mpa						
DURATION : 1 MINUTES						
LEAKAGE OK						

RELATIVE STANDARD						
STANDARD	BS 21:1985(BSPT)					

MATERIAL CERTIFICATE															
DESCRIPTION	CHEMICAL COMPOSITION (%)								MECHANICAL PROPERTIES						
	HEAT NO.	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	V	TENSILE Mpa	YIELD Mpa	ELONGATION %	REDUCE AREA %
Body	N/A	3.6	0.7	0.04	0.06	2.1	-	0.01	0.02	-	-	208	-	-	-
Cap	N/A	3.6	0.7	0.04	0.06	2.1	-	0.01	0.02	-	-	208	-	-	-
Screen	N/A	0.05	1.2	0.03	-	0.46	-	8.28	18.3	-	-	-	658	-	-

REMARK: IN ACCORDANCE WITH EN 10204.3.1B

HEREBY, WE CERTIFY THAT THE NOMINATED PRODUCTS ARE QUALIFIED AND COMPLIANCE IN:

1.MAIN COMPONENTS OF NATIONAL STANDARD OR / RELATIVE CRITERION.

2.CONNECTION SIZE OF NATIONAL STANDARD OR / RELATIVE CRITERION.

3.QUEST OF CLIENT OR P.O. SPECIFIED

ARITA VALVE MFG. (M) SDN. BHD.

