



ARITA VALVE QUALITY & PRODUCT INSPECTION REPORT

| | | | | | | |
|---------------|-------------------------|-----------|----------|--------|------------------|-----------------|
| P/O NO | MODEL | MODEL NO | PRESSURE | QTY | NOMINAL DIAMETER | DATE |
| APO-2203-0090 | ARITA CI Y-Strainer F/E | ARF-805FE | PN16 | 10 pcs | DN100 (4") | 15TH.MARCH.2022 |

PRESSURE TEST

| | |
|---------------------------|----|
| HYDROSTATIC PRESSURE TEST | |
| PRESSURE : 15 Bar | |
| DURATION : 2 MINUTES | |
| LEAKAGE | OK |

RELATIVE STANDARD

| | |
|----------|--------|
| STANDARD | BS4504 |
|----------|--------|

MATERIAL CERTIFICATE

| DESCRIPTION | CHEMICAL COMPOSITION (%) | | | | | | | | | | MECHANICAL PROPERTIES | | | | | |
|-------------|--------------------------|------|-----|------|------|------|----|------|------|----|-----------------------|-------|-------------|-----------|--------------|---------------|
| | HEAT NO. | C | Mn | P | S | Si | Cu | Ni | Cr | Mo | V | Other | TENSILE Mpa | YIELD Mpa | ELONGATION % | REDUCE AREA % |
| Body | N/A | 3.5 | 0.7 | 0.03 | 0.02 | 2.5 | - | - | - | - | - | - | 205 | - | - | - |
| Screen | N/A | 0.05 | 1.2 | 0.03 | - | 0.46 | - | 8.28 | 18.3 | - | - | - | 658 | - | - | - |


REMARK: IN ACCORDANCE WITH EN 10204.3.1B

HEREBY, WE CERTIFY THAT THE NOMINATED PRODUCTS ARE QUALITIED AND COMPLIANCE IN:


1.MAIN COMPONENTS OF NATIONAL STANDARD OR / RELATIVE CRITERION.

2.CONNECTION SIZE OF NATIONAL STANDARD OR / RELATIVE CRITERION.

3.QUEST OF CLIENT OR P.O. SPECIFIED




ARITA VALVE MFG. (M) SDN. BHD.



ARITA VALVE QUALITY & PRODUCT INSPECTION REPORT

| | | | | | | | | | | | | | | | | | |
|---|-------------------------|--------------------------|----------|-------|------------------|-----------------|-----------------------|----|------|------|----|---|-------|-------------|--------------------------------|--------------|---------------|
| P/O NO | MODEL | MODEL NO | PRESSURE | QTY | NOMINAL DIAMETER | DATE | | | | | | | | | | | |
| APO-2203-0090 | ARITA CI Y-Strainer F/E | ARF-805FE | PN16 | 2 pcs | DN200 (8") | 15TH.MARCH.2022 | | | | | | | | | | | |
| PRESSURE TEST | | | | | | | | | | | | | | | | | |
| HYDROSTATIC PRESSURE TEST | | | | | | | | | | | | | | | | | |
| PRESSURE : 15 Bar | | | | | | | | | | | | | | | | | |
| DURATION : 2 MINUTES | | | | | | | | | | | | | | | | | |
| LEAKAGE OK | | | | | | | | | | | | | | | | | |
| RELATIVE STANDARD | | | | | | | | | | | | | | | | | |
| STANDARD BS4504 | | | | | | | | | | | | | | | | | |
| MATERIAL CERTIFICATE | | | | | | | | | | | | | | | | | |
| DESCRIPTION | | CHEMICAL COMPOSITION (%) | | | | | MECHANICAL PROPERTIES | | | | | | | | | | |
| PART | MATERIAL | HEAT NO. | C | Mn | P | S | Si | Cu | Ni | Cr | Mo | V | Other | TENSILE Mpa | YIELD Mpa | ELONGATION % | REDUCE AREA % |
| Body | FC 200 | N/A | 3.5 | 0.7 | 0.03 | 0.02 | 2.5 | - | - | - | - | - | - | 205 | - | - | - |
| Screen | SUS 304 | N/A | 0.05 | 1.2 | 0.03 | - | 0.46 | - | 8.28 | 18.3 | - | - | - | 658 | - | - | - |
| REMARK: IN ACCORDANCE WITH EN 10204.3.1B | | | | | | | | | | | | | | | | | |
| HEREBY, WE CERTIFY THAT THE NOMINATED PRODUCTS ARE QUALIFIED AND COMPLIANCE IN: | | | | | | | | | | | | | | | | | |
| 1.MAIN COMPONENTS OF NATIONAL STANDARD OR / RELATIVE CRITERION. | | | | | | | | | | | | | | | | | |
| 2.CONNECTION SIZE OF NATIONAL STANDARD OR / RELATIVE CRITERION. | | | | | | | | | | | | | | | | | |
| 3.QUEST OF CLIENT OR P.O. SPECIFIED | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | ARITA VALVE MFG. (M) SDN. BHD. | | |



ARITA VALVE QUALITY & PRODUCT INSPECTION REPORT

| | | | | | | |
|---------------|-------------------------|-----------|----------|-------|------------------|-----------------|
| P/O NO | MODEL | MODEL NO | PRESSURE | QTY | NOMINAL DIAMETER | DATE |
| APO-2203-0090 | ARITA CI Y-Strainer F/E | ARF-805FE | PN16 | 3 pcs | DN250 (10") | 15TH.MARCH.2022 |

| | |
|---------------------------|----|
| PRESSURE TEST | |
| HYDROSTATIC PRESSURE TEST | |
| PRESSURE : 15 Bar | |
| DURATION : 2 MINUTES | |
| LEAKAGE | OK |

| | |
|-------------------|--------|
| RELATIVE STANDARD | |
| STANDARD | BS4504 |

| MATERIAL CERTIFICATE | | | | | | | | | | | | | | | | |
|----------------------|--------------------------|------|-----|------|------|------|----|------|------|----|-----------------------|-------|-------------|-----------|--------------|---------------|
| DESCRIPTION | CHEMICAL COMPOSITION (%) | | | | | | | | | | MECHANICAL PROPERTIES | | | | | |
| | HEAT NO. | C | Mn | P | S | Si | Cu | Ni | Cr | Mo | V | Other | TENSILE Mpa | YIELD Mpa | ELONGATION % | REDUCE AREA % |
| Body | N/A | 3.5 | 0.7 | 0.03 | 0.02 | 2.5 | - | - | - | - | - | - | 205 | - | - | - |
| Screen | N/A | 0.05 | 1.2 | 0.03 | - | 0.46 | - | 8.28 | 18.3 | - | - | - | 658 | - | - | - |



REMARK: IN ACCORDANCE WITH EN 10204.3.1B

HEREBY, WE CERTIFY THAT THE NOMINATED PRODUCTS ARE QUALITIED AND COMPLIANCE IN:

1.MAIN COMPONENTS OF NATIONAL STANDARD OR / RELATIVE CRITERION.

2.CONNECTION SIZE OF NATIONAL STANDARD OR / RELATIVE CRITERION.

3.QUEST OF CLIENT OR P.O. SPECIFIED



 ARITA VALVE MFG. (M) SON BHD