


ARITA VALVE QUALITY & PRODUCT INSPECTION REPORT

P/O NO	MODEL	MODEL NO	PRESSURE	QTY	NOMINAL DIAMETER	DATE											
APO-2203-0090	ARITA CI Y-Strainer F/E	ARF-805FE	Table E	4 pcs	DN80 (3")	15TH.MARCH.2022											
PRESSURE TEST																	
HYDROSTATIC PRESSURE TEST																	
PRESSURE : 15 Bar																	
DURATION : 2 MINUTES																	
LEAKAGE OK																	
RELATIVE STANDARD																	
STANDARD BS 10																	
MATERIAL CERTIFICATE																	
DESCRIPTION		CHEMICAL COMPOSITION (%)					MECHANICAL PROPERTIES										
PART	MATERIAL	HEAT NO.	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	V	Other	TENSILE Mpa	YIELD Mpa	ELONGATION %	REDUCE AREA %
Body	FC 200	N/A	3.5	0.7	0.03	0.02	2.5	-	-	-	-	-	-	205	-	-	-
Screen	SUS 304	N/A	0.05	1.2	0.03	-	0.46	-	8.28	18.3	-	-	-	658	-	-	-
REMARK: IN ACCORDANCE WITH EN 10204.3.1B																	
HEREBY, WE CERTIFY THAT THE NOMINATED PRODUCTS ARE QUALIFIED AND COMPLIANCE IN:																	
1.MAIN COMPONENTS OF NATIONAL STANDARD OR / RELATIVE CRITERION.																	
2.CONNECTION SIZE OF NATIONAL STANDARD OR / RELATIVE CRITERION.																	
3.QUEST OF CLIENT OR P.O. SPECIFIED																	
 															ARITA VALVE MFG. (M) SDN. BHD.		



ARITA VALVE QUALITY & PRODUCT INSPECTION REPORT


P/O NO	MODEL	MODEL NO	PRESSURE	QTY	NOMINAL DIAMETER	DATE											
APO-2203-0090	ARITA CI Y-Strainer F/E	ARF-805FE	Table E	2 pcs	DN125 (5")	15TH.MARCH.2022											
PRESSURE TEST																	
HYDROSTATIC PRESSURE TEST																	
PRESSURE : 15 Bar																	
DURATION : 2 MINUTES																	
LEAKAGE OK																	
RELATIVE STANDARD																	
STANDARD BS 10																	
MATERIAL CERTIFICATE																	
CHEMICAL COMPOSITION (%)																	
DESCRIPTION	MECHANICAL PROPERTIES																
PART	MATERIAL	HEAT NO.	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	V	Other	TENSILE Mpa	YIELD Mpa	ELONGATION %	REDUCE AREA %
Body	FC 200	N/A	3.5	0.7	0.03	0.02	2.5	-	-	-	-	-	-	205	-	-	-
Screen	SUS 304	N/A	0.05	1.2	0.03	-	0.46	-	8.28	18.3	-	-	-	658	-	-	-
REMARK: IN ACCORDANCE WITH EN 10204.3.1B																	
HEREBY, WE CERTIFY THAT THE NOMINATED PRODUCTS ARE QUALIFIED AND COMPLIANCE IN:																	
1.MAIN COMPONENTS OF NATIONAL STANDARD OR / RELATIVE CRITERION.																	
2.CONNECTION SIZE OF NATIONAL STANDARD OR / RELATIVE CRITERION.																	
3.QUEST OF CLIENT OR P.O. SPECIFIED																	



ARITA VALVE MFG. (M) SDN BHD.



ARITA VALVE QUALITY & PRODUCT INSPECTION REPORT

P/O NO	MODEL	MODEL NO	PRESSURE	QTY	NOMINAL DIAMETER	DATE											
APO-2203-0090	ARITA CI Y-Strainer F/E	ARF-805FE	Table E	5 pcs	DN200 (8")	15TH.MARCH.2022											
PRESSURE TEST																	
HYDROSTATIC PRESSURE TEST																	
PRESSURE : 15 Bar																	
DURATION : 2 MINUTES																	
LEAKAGE OK																	
RELATIVE STANDARD																	
STANDARD BS 10																	
MATERIAL CERTIFICATE																	
DESCRIPTION		CHEMICAL COMPOSITION (%)						MECHANICAL PROPERTIES									
PART	MATERIAL	HEAT NO.	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	V	Other	TENSILE Mpa	YIELD Mpa	ELONGATION %	REDUCE AREA %
Body	FC 200	N/A	3.5	0.7	0.03	0.02	2.5	-	-	-	-	-	-	205	-	-	-
Screen	SUS 304	N/A	0.05	1.2	0.03	-	0.46	-	8.28	18.3	-	-	-	658	-	-	-
REMARK: IN ACCORDANCE WITH EN 10204.3.1B																	
HEREBY, WE CERTIFY THAT THE NOMINATED PRODUCTS ARE QUALIFIED AND COMPLIANCE IN:																	
1.MAIN COMPONENTS OF NATIONAL STANDARD OR / RELATIVE CRITERION.																	
2.CONNECTION SIZE OF NATIONAL STANDARD OR / RELATIVE CRITERION.																	
3.QUEST OF CLIENT OR P.O. SPECIFIED																	
																	
ARITA VALVE MFG. (M) SDN. BHD.																	